

# X20(c)CS1020

## 1 General information

In addition to the standard I/O, complex devices often need to be connected. The X20CS communication modules are intended precisely for cases like this. As normal X20 electronics modules, they can be placed anywhere on the remote backplane.

- RS232 interface for serial, remote connection of complex devices to the X20 system

## 2 Coated modules

Coated modules are X20 modules with a protective coating for the electronics component. This coating protects X20c modules from condensation and corrosive gases.

The modules' electronics are fully compatible with the corresponding X20 modules.

**For simplification purposes, only images and module IDs of uncoated modules are used in this data sheet.**

The coating has been certified according to the following standards:

- Condensation: BMW GS 95011-4, 2x 1 cycle
- Corrosive gas: EN 60068-2-60, method 4, exposure 21 days



## 3 Order data

Model number	Short description	Figure
	<b>X20 electronics module communication</b>	
X20CS1020	X20 interface module, 1 RS232 interface, max. 115.2 kbit/s	
X20cCS1020	X20 interface module, coated, 1 RS232 interface, max. 115.2 kbit/s	
	<b>Required accessories</b>	
	<b>Bus modules</b>	
X20BM11	X20 bus module, 24 VDC keyed, internal I/O supply continuous	
X20BM15	X20 bus module, with node number switch, 24 VDC keyed, internal I/O supply continuous	
X20cBM11	X20 bus module, coated, 24 VDC keyed, internal I/O supply continuous	
	<b>Terminal blocks</b>	
X20TB06	X20 terminal block, 6-pin, 24 VDC keyed	
X20TB12	X20 terminal block, 12-pin, 24 VDC keyed	

Table 1: X20CS1020, X20cCS1020 - Order data

## 4 Technical data

Model number	X20CS1020	X20cCS1020
<b>Short description</b>		
Communication module	1x RS232	
<b>General information</b>		
B&R ID code	0x1FCF	0xE7F2
Status indicators	Data transfer, operating status, module status	
<b>Diagnostics</b>		
Module run/error	Yes, using status LED and software	
Data transfer	Yes, using status LED	
<b>Power consumption</b>		
Bus	0.01 W	
Internal I/O	1.44 W	
Additional power dissipation caused by actuators (resistive) [W]	-	
<b>Certifications</b>		
CE	Yes	
ATEX	Zone 2, II 3G Ex nA nC IIA T5 Gc IP20, Ta (see X20 user's manual) FTZÚ 09 ATEX 0083X	
UL	cULus E115267 Industrial control equipment	
HazLoc	cCSAus 244665 Process control equipment for hazardous locations Class I, Division 2, Groups ABCD, T5	
DNV GL	Temperature: <b>B</b> (0 - 55°C) Humidity: <b>B</b> (up to 100%) Vibration: <b>B</b> (4 g) EMC: <b>B</b> (bridge and open deck)	
LR	ENV1	
KR	Yes	
ABS	Yes	
EAC	Yes	
KC	Yes	-
<b>Interfaces</b>		
Interface IF1		
Signal	RS232	
Variant	Connection made using 12-pin X20TB12 terminal block	
Max. distance	900 m	
Transfer rate	Max. 115.2 kbit/s	
FIFO buffer	1 kB	
Handshake lines	RTS, CTS	
Controller	UART type 16C550 compatible	
<b>Electrical properties</b>		
Electrical isolation	RS232 (IF1) isolated from bus RS232 (IF1) not isolated from I/O power supply	
<b>Operating conditions</b>		
Mounting orientation		
Horizontal	Yes	
Vertical	Yes	
Installation elevation above sea level		
0 to 2000 m	No limitations	
>2000 m	Reduction of ambient temperature by 0.5°C per 100 m	
Degree of protection per EN 60529	IP20	
<b>Ambient conditions</b>		
Temperature		
Operation		
Horizontal mounting orientation	-25 to 60°C	
Vertical mounting orientation	-25 to 50°C	
Derating	See section "Derating"	
Storage	-40 to 85°C	
Transport	-40 to 85°C	
Relative humidity		
Operation	5 to 95%, non-condensing	Up to 100%, condensing
Storage	5 to 95%, non-condensing	
Transport	5 to 95%, non-condensing	
<b>Mechanical properties</b>		
Note	Order 1x X20TB06 or X20T-B12 terminal block separately Order 1x X20BM11 bus module separately	Order 1x X20TB06 or X20T-B12 terminal block separately Order 1x X20cBM11 bus module separately
Pitch	12.5 <sup>+0.2</sup> mm	

Table 2: X20CS1020, X20cCS1020 - Technical data


## 5 LED status indicators

For a description of the various operating modes, see section "Additional information - Diagnostic LEDs" of the X20 system user's manual.

Figure	LED	Color	Status	Description
	r	Green	Off	No power to module
			Single flash	RESET mode
			Double flash	BOOT mode (during firmware update) <sup>1)</sup>
			Blinking	PREOPERATIONAL mode
			On	RUN mode
	e	Red	Off	No power to module or everything OK
			Single flash	An I/O error has occurred, see "Error message status bits" on page 15
			On	Error or reset status
	e + r	Red on / Green single flash	Invalid firmware	
Tx	Yellow	On	The module transmits data via the RS232 interface.	
Rx	Yellow	On	The module receives data via the RS232 interface.	

1) Depending on the configuration, a firmware update can take up to several minutes.

## 6 Pinout




## 7 Derating

There is no derating when operated below 55°C.

During operation over 55°C, the power dissipation of the modules to the left and right of this module is not permitted to exceed 1.15 W!

For an example of calculating the power dissipation of I/O modules, see section "Mechanical and electrical configuration - Power dissipation of I/O modules" in the X20 user's manual.



## 8 UL certificate information

To install the module according to the UL standard, the following rules must be observed.

### Information:

- **Use copper conductors only. Minimum temperature rating of the cable to be connected to the field wiring terminals: 61°C, 28 - 14 AWG.**
- **All models are intended to be used in a final safety enclosure that must conform with requirements for protection against the spread of fire and have adequate rigidity per UL 61010-1 and UL 61010-2-201.**
- **The external circuits intended to be connected to the device shall be galv. separated from mains supply or hazardous live voltage by reinforced or double insulation and meet the requirements of SELV/PELV circuit.**
- **If the equipment is used in not specified manner, the protection provided by the equipment may be impaired.**
- **Repairs can only be made by B&R.**

## 9 Register description

### 9.1 General data points

In addition to the registers described in the register description, the module has additional general data points. These are not module-specific but contain general information such as serial number and hardware variant.

General data points are described in section "Additional information - General data points" of the X20 system user's manual.

### 9.2 Function model 2 - Stream and Function model 254 - Cyclic stream

Function models "Stream" and "Cyclic stream" use a module-specific driver for the operating system. The interface can be controlled using library "DvFrame" and reconfigured at runtime.

#### Function model - Stream

In function model "Stream", the CPU communicates with the module acyclically. The interface is relatively convenient, but the timing is very imprecise.

#### Function model - Cyclic stream

Function model "Cyclic stream" was implemented later. From the application's point of view, there is no difference between function models "Stream" and "Cyclic stream". Internally, however, the cyclic I/O registers are used to ensure that communication follows deterministic timing.

#### Information:

- In order to use function models "Stream" and "Cyclic stream", you must be using B&R controllers of type "SG4".
- These function models can only be used in X2X Link and POWERLINK networks.

Register	Name	Data type	Read		Write	
			Cyclic	Acyclic	Cyclic	Acyclic
<b>Module - Configuration</b>						
-	AsynSize	-				
<b>Status messages – Configuration</b>						
50	CfO_RxStateIgnoreMask	UINT				•
6273	CfO_ErrorID0007	USINT				•
<b>Status messages – Communication</b>						
6145	ErrorByte	USINT	•			
	StartBitError	Bit 0				
	StopBitError	Bit 1				
	ParityError	Bit 2				
	RXoverrun	Bit 3				
6209	ErrorQuitByte	USINT			•	
	QuitStartBitError	Bit 0				
	QuitStopBitError	Bit 1				
	QuitParityError	Bit 2				
	QuitRXoverrun	Bit 3				

### 9.3 Function model 254 - Flatstream

Flatstream provides independent communication between an X2X Link master and the module. This interface was implemented as a separate function model for the module. Serial information is transferred via cyclic input and output registers. The sequence and control bytes are used to control the data stream (see "Flatstream communication" on page 16).

When using function model Flatstream, the user can choose whether to use library "AsFltGen" in AS for implementation or to adapt Flatstream handling directly to the individual requirements of the application.

Register	Name	Data type	Read		Write	
			Cyclic	Acyclic	Cyclic	Acyclic
<b>Serial interface - Configuration</b>						
1	phyMode	USINT				•
12	phyBaud	UDINT				•
3	phyData	USINT				•
5	phyStop	USINT				•
7	phyParity	USINT				•
<b>Handshake – Configuration</b>						
66	rxLock	UINT				•
70	rxUnlock	UINT				•
34	hssXOn	UINT				•
38	hssXOff	UINT				•
42	hssPeriod	UINT				•
19	hshTxF	USINT				•
29	hshRxF	USINT				•
27	hshSet	USINT				•
25	hshClr	USINT				•
17	hshInv	USINT				•
<b>Frame – Configuration</b>						
74	rxCto	UINT				•
106	txCto	UINT				•
78	rxEomSize	UINT				•
110	txEomSize	UINT				•
Index * 4 + 82	rxEomCharN (index N = 0 to 3)	UINT				•
Index * 4 + 114	txEomCharN (index N = 0 to 3)	UINT				•
<b>Status messages – Configuration</b>						
50	Cfo_RxStateIgnoreMask	UINT				•
6273	Cfo_ErrorID0007	USINT				•
<b>Status messages – Communication</b>						
6145	ErrorByte	USINT	•			
	StartBitError	Bit 0				
	StopBitError	Bit 1				
	ParityError	Bit 2				
	RXoverrun	Bit 3				
6209	ErrorQuitByte	USINT		•		
	QuitStartBitError	Bit 0				
	QuitStopBitError	Bit 1				
	QuitParityError	Bit 2				
	QuitRXoverrun	Bit 3				
<b>Flatstream</b>						
225	OutputMTU	USINT				•
227	InputMTU	USINT				•
229	Mode	USINT				•
231	Forward	USINT				•
238	ForwardDelay	UINT				•
128	InputSequence	USINT	•			
Index + 128	RxByteN (index N = 1 to 27)	USINT	•			
160	OutputSequence	USINT			•	
Index + 160	TxByteN (index N = 1 to 27)	USINT			•	

## 9.4 Function model 254 - Bus controller

Function model "Bus controller" is a reduced form of function model "Flatstream". Instead of up to 27 Tx / Rx bytes, a maximum of 7 Tx / Rx bytes can be used.

Register	Offset <sup>1)</sup>	Name	Data type	Read		Write	
				Cyclic	Acyclic	Cyclic	Acyclic
<b>Serial interface - Configuration</b>							
257	-	phyMode_CANIO	USINT				•
268	-	phyBaud_CANIO	UDINT				•
259	-	phyData_CANIO	USINT				•
261	-	phyStop_CANIO	USINT				•
263	-	phyParity_CANIO	USINT				•
<b>Handshake – Configuration</b>							
322	-	rxILock_CANIO	UINT				•
326	-	rxIUnlock_CANIO	UINT				•
290	-	hssXOn_CANIO	UINT				•
294	-	hssXOff_CANIO	UINT				•
298	-	hssPeriod_CANIO	UINT				•
275	-	hshTxF_CANIO	USINT				•
285	-	hshRxF_CANIO	USINT				•
281	-	hshClr_CANIO	USINT				•
283	-	hshSet_CANIO	USINT				•
287	-	hshFrm_CANIO	USINT				•
273	-	hshInv_CANIO	USINT				•
<b>Frame – Configuration</b>							
330	-	rxCto_CANIO	UINT				•
362	-	txCto_CANIO	UINT				•
334	-	rxEomSize_CANIO	UINT				•
366	-	txEomSize_CANIO	UINT				•
Index*4 + 338	-	rxEomCharN (N = 0 to 3)	UINT				•
Index*4 + 370	-	txEomCharN (N = 0 to 3)	UINT				•
<b>Status messages – Configuration</b>							
306	-	CfO_RxStateIgnoreMask_CANIO	UINT				•
6273	-	CfO_ErrorID0007	USINT				•
<b>Status messages – Communication</b>							
6145	-	ErrorByte	USINT		•		
		StartBitError	Bit 0				
		StopBitError	Bit 1				
		ParityError	Bit 2				
		RXoverrun	Bit 3				
6209	-	ErrorQuitByte	USINT				•
		QuitStartBitError	Bit 0				
		QuitStopBitError	Bit 1				
		QuitParityError	Bit 2				
		QuitRXoverrun	Bit 3				
<b>Flatstream</b>							
225	-	OutputMTU	USINT				•
227	-	InputMTU	USINT				•
229	-	Mode	USINT				•
231	-	Forward	USINT				•
238	-	ForwardDelay	UINT				•
128	0	InputSequence	USINT	•			
Index + 128	Index	RxByteN (index N = 1 to 7)	USINT	•			
160	0	OutputSequence	USINT			•	
Index + 160	Index	TxByteN (index N = 1 to 7)	USINT			•	

1) The offset specifies the position of the register within the CAN object.

### 9.4.1 Using the module on the bus controller

Function model 254 "Bus controller" is used by default only by non-configurable bus controllers. All other bus controllers can use other registers and functions depending on the fieldbus used.

For detailed information, see section "Additional information - Using I/O modules on the bus controller" of the X20 user's manual (version 3.50 or later).

### 9.4.2 CAN I/O bus controller

The module occupies 1 analog logical slot on CAN I/O.

## 9.5 Serial interface - Configuration

The user has to configure 5 registers to operate the serial interface.

### 9.5.1 Mode

Name:

phyMode

phyMode\_CANIO

This register is used to determine the current operating mode of the interface.

Enabling the interface is only permitted after complete configuration of the other registers. If parameters need to be changed, the interface must first be disabled.

Data type	Value	Description
USINT	0	RS232 interface disabled (default)
	2	RS232 interface enabled

### 9.5.2 Baud rate

Name:

phyBaud

phyBaud\_CANIO

This register sets the baud rate of the interface in bit/s.

Data type	Value	Function
UDINT	1200	1.2 kbaud
	2400	2.4 kbaud
	4800	4.8 kbaud
	9600	9.6 kbaud
	19200	19.2 kbaud
	38400	38.4 kbaud
	57600	57.6 kbaud (bus controller default setting)
	115200	115.2 kbaud

### 9.5.3 Number of data bits

Name:

phyData

phyData\_CANIO

This register is used to specify the number of bits to be transferred for each character.

Data type	Value	Description
USINT	7	7 data bits
	8	8 data bits (bus controller default setting)

### 9.5.4 Number of stop bits

Name:

phyStop

phyStop\_CANIO

This register is used to define the number of stop bits.

Data type	Values	Explanation
USINT	2	1 stop bit (bus controller default setting)
	4	2 stop bits

### 9.5.5 Type of parity check

Name:

phyParity

phyParity\_CANIO

This register is used to define the parity check type. Possible values are ASCII coded.

Data type	Value	Description
USINT	48	"0" - (low) bit is always 0
	49	"1" - (high) bit is always 1
	69	"E" - (even) even parity (bus controller default setting)
	78	"N" - (no) no bit
	79	"O" - (odd) odd parity

### 9.6 Handshake - Configuration

In order to guarantee that serial communication runs smoothly, the size of the receive buffer in the module must be known. In addition, the user can configure a software or hardware handshake algorithm.

#### 9.6.1 Locking the receive buffer

Name:

rxILock

rxILock\_CANIO

This register is used to configure the upper threshold of the receive buffer.

The two registers "Lock" and "Unlock" can be used for "flow control" monitoring of the communication. If the amount of data from the module input exceeds the value of register "Lock", flow control switches to state "Passive". To return to state "Active" or "Ready", the amount of data in the receive buffer must fall below the default value of register "Unlock".

#### Information:

**These registers simulate the behavior of a Schmitt trigger, so the value of register "Lock" must be greater than the value of register "Unlock".**

Data type	Value	Description
UINT	0 to 4095	Upper limit of receive buffer. Bus controller default setting: 1024

#### 9.6.2 Unlocking the receive buffer

Name:

rxIUnlock

rxIUnlock\_CANIO

This register is used to configure the lower threshold of the receive buffer.

The two registers "Lock" and "Unlock" can be used for "flow control" monitoring of the communication. If the amount of data from the module input exceeds the value of register "Lock", flow control switches to state "Passive". To return to state "Active" or "Ready", the amount of data in the receive buffer must fall below the default value of register "Unlock".

#### Information:

**These registers simulate the behavior of a Schmitt trigger, so the value of register "Lock" must be greater than the value of register "Unlock".**

Data type	Value	Description
UINT	0 to 4095	Lower limit of receive buffer. Bus controller default setting: 512

### 9.6.3 RTS evaluation

Name:  
hshRxF  
hshRxF\_CANIO

These registers can be used to configure how the hardware handshake line RTS is controlled depending on the fill level of the receive buffer.

The two registers "TxF" and 'RxF" can be used to enable flow control for the input or output direction. Communication takes place here via a ring buffer.

#### Information:

**Only one hsh register can be configured for controlling the RTS line.**

Data type	Value	Description
USINT	0	RTS line freely available for other flow control methods (bus controller default setting)
	16	RTS line is controlled by the fill level of the receive buffer

### 9.6.4 CTS evaluation

Name:  
hshTxF  
hshTxF\_CANIO

This register is used to configure how the CTS hardware handshake line is evaluated. Make sure wiring to the peer station is correct when CTS query is enabled.

The two registers "TxF" and 'RxF" can be used to enable flow control for the input or output direction. Communication takes place here via a ring buffer.

Data type	Value	Description
USINT	0	CTS line ignored, transmission can take place at any time (bus controller default setting)
	1	CTS line active and is being used for flow control, transmit enable from the peer station

### 9.6.5 Turn on software handshake

Name:  
hssXOn  
hssXOn\_CANIO

This register can be used to configure the XOn character. The value 17 is the default, but any other value can also be configured.

The two registers "Xon" and "Xoff" can be used to initiate a software handshake for flow control. A valid ASCII character must be configured in both registers for this.

Data type	Value	Description
UINT	0 to 255	XOn ASCII character
	65535	No software handshake (bus controller default setting)

### 9.6.6 Turn off software handshake

Name:  
hssXOff  
hssXOff\_CANIO

This register can be used to configure the XOff character. The value 19 is the default, but any other value can also be configured.

The two registers "Xon" and "Xoff" can be used to initiate a software handshake for flow control. A valid ASCII character must be configured in both registers for this.

Data type	Value	Description
UINT	0 to 255	XOff ASCII character
	65535	No software handshake (bus controller default setting)

### 9.6.7 Handshake repetition

Name:

hssPeriod

hssPeriod\_CANIO

When using a software handshake, some applications require periodic repetition of the current status. The repeat time can be defined in this register in ms for this purpose.

Data type	Value	Description
UINT	0	Automatic status repeat disabled
	500 to 10000	Retry interval in ms. Bus controller default setting: 5000

### 9.6.8 Enable handshake manually

Name:

hshSet

hshSet\_CANIO

The two registers "Set" and "Clr" can be used to manually manage the handshake via the application.

These registers can be used to force the output level of the RTS hardware handshake line to remain active.

#### Information:

**Only one hsh register can be configured for controlling the RTS line.**

Data type	Value	Description
USINT	0	RTS line freely available for other flow control methods (bus controller default setting)
	16	RTS line enabled

### 9.6.9 Disable handshake manually

Name:

hshClr

hshClr\_CANIO

The two registers "Set" and "Clr" can be used to manually manage the handshake via the application.

These registers can be used to force the output level of the RTS hardware handshake line to remain passive.

#### Information:

**Only one hsh register can be configured for controlling the RTS line.**

Data type	Value	Description
USINT	0	RTS line freely available for other flow control methods (bus controller default setting)
	16	RTS line disabled

### 9.6.10 Frame detection

Name:

hshFrm

hshFrm\_CANIO

This register generally enables hardware-based frame detection. The RTS line is enabled as long as data is being transmitted. This Tx framing mode can be used to control external interface converters.

#### Information:

**Only one hsh register can be configured for controlling the RTS line.**

Data type	Values	Explanation
USINT	0	RTS line freely available for other flow control methods (bus controller default setting)
	16	Tx framing enabled for RTS line
	80	Tx framing enabled for RTS line (without echo)

### 9.6.11 Inverting RTS/CTS

Name:  
hshInv  
hshInv\_CANIO

This register can be used to create a logical inverse of the RTS/CTS signals.

Data type	Values	Bus controller default setting
USINT	See the bit structure.	0

Bit structure:

Bit	Description	Value	Information
0	CTS signal	0	Inversion off (bus controller default setting)
		1	Inversion on
1 - 3	Reserved	0	
4	RTS signal	0	Inversion off (bus controller default setting)
		1	Inversion on
5 - 7	Reserved	0	

### 9.7 Frame - Configuration

Different message termination codes can be specified in order to correctly create transmitted Tx frames and correctly interpret received Rx frames.

#### 9.7.1 Terminating when a receive timeout occurs

Name:  
rxCto  
rxCto\_CANIO

This register is used to set the duration until a receive timeout is triggered.

The message is considered to be terminated when nothing is transferred for the specified duration. The time is specified here in characters to ensure that it is independent of the transfer rate. The number of characters is then multiplied by the time needed to transfer a character.

Data type	Value	Description
UINT	0	Function disabled
	1 to 65535	Receive timeout in characters. Bus controller default setting: 4

#### 9.7.2 Terminating when a transmit timeout occurs

Name:  
txCto  
txCto\_CANIO

This register is used to set the duration until a transmit timeout is triggered.

The message is considered to be terminated when nothing is transferred for the specified duration. The time is specified here in characters to ensure that it is independent of the transfer rate. The number of characters is then multiplied by the time needed to transfer a character.

Data type	Value	Description
UINT	0	Function disabled
	1 to 65535	Transmit timeout in characters. Bus controller default setting: 5

### 9.7.3 Maximum number of bytes received

Name:

rxEomSize

rxEomSize\_CANIO

These registers configure the maximum number of bytes in the receive frame.

The message is considered to be ended as soon as a frame with the specified size in bytes is transferred. The longest possible frame length is the size of the 4096-byte receive buffer. Larger frames cause the Receive Overrun error.

Data type	Value	Description
UINT	0	Function disabled
	1 to 4096	Configurable receive frame length in characters. Bus controller default setting: 256

### 9.7.4 Maximum number of bytes transmitted

Name:

txEomSize

txEomSize\_CANIO

These registers configure the maximum number of bytes in the transmit frame.

The message is considered to be ended as soon as a frame with the specified size in bytes is transferred. The longest possible frame length is the size of the 4096-byte transmit buffer. The configured transmit timeout is maintained after the frame has been sent.

Data type	Value	Description
UINT	0	Function disabled
	1 to 4096	Configurable transmit frame length in characters. Bus controller default setting: 4096

### 9.7.5 Define receive terminator

Name:

rxEomChar0 to rxEomChar3

rxEomChar0\_CANIO to rxEomChar3\_CANIO

It is possible to configure a receive terminator for all registers.

The message is considered to be terminated as soon as one of the defined characters is transferred.

Data type	Value	Description
UINT	0 to 255	Frame terminator (ASCII code)
	65535	Function disabled (bus controller default setting)

### 9.7.6 Define transmit terminator

Name:

txEomChar0 to txEomChar3

txEomChar0\_CANIO to txEomChar3\_CANIO

It is possible to configure a transmit terminator for all registers.

The message is considered to be terminated as soon as one of the defined characters is transferred.

Data type	Value	Description
UINT	0 to 255	Frame terminator (ASCII code)
	65535	Function disabled (bus controller default setting)

## 9.8 Status messages - Configuration

The status messages provide the user with information about the current situation in the downstream serial network.

### 9.8.1 Error detection setting

Name:

CfO\_RxStatelgnoreMask

CfO\_RxStatelgnoreMask\_CANIO

This register has a direct effect on UART operation. Error detection in general can be disabled using the low byte. If error detection is not disabled, the high byte can be used to specify that a detected error should be interpreted as the end of the message.

Data type	Values	Bus controller default setting
UINT	See bit structure.	0

Bit structure:

Bit	Name	Value	Information
0 - 3	Reserved	0	
4	StartBitError	0	Detect invalid start bit (bus controller default setting)
		1	Ignore
5	StopBitError	0	Detect invalid stop bit (bus controller default setting)
		1	Ignore
6	ParityError	0	Detect invalid parity bit (bus controller default setting)
		1	Ignore
7	RXoverrun	0	Detect overflow in receive direction (bus controller default setting)
		1	Ignore
8 - 11	Reserved	0	
12	StartBitError corresponds to the end of the frame (if bit 4 = 0)	0	Indicate error in module only (bus controller default setting)
		1	Also signal end of frame
13	StopBitError corresponds to the end of the frame (if bit 5 = 0)	0	Indicate error in module only (bus controller default setting)
		1	Also signal end of frame
14	ParityError corresponds to the end of the frame (if bit 6 = 0)	0	Indicate error in module only (bus controller default setting)
		1	Also signal end of frame
15	RXoverrun corresponds to the end of the frame (if bit 7 = 0)	0	Indicate error in module only (bus controller default setting)
		1	Also signal end of frame

### 9.8.2 Forward error to the application

Name:

CfO\_ErrorID0007

This register sets which error messages are forwarded to the application.

Data type	Values	Bus controller default setting
USINT	See the bit structure.	0

Bit structure:

Bit	Name	Value	Information
0	StartBitError	0	Ignore (bus controller default setting)
		1	Indicating a faulty start bit
1	StopBitError	0	Ignore (bus controller default setting)
		1	Indicating a faulty stop bit
2	ParityError	0	Ignore (bus controller default setting)
		1	Indicating a faulty parity bit
3	RXoverrun	0	Ignore (bus controller default setting)
		1	Indicating an overflow in the receive direction
4 - 7	Reserved	0	

## 9.9 Status messages - Communication

After configuration is completed, up to four status messages can be evaluated in the application.

### 9.9.1 Error message status bits

Name:  
StartBitError  
StopBitError  
ParityError  
RXoverrun

This register transfers the individual bits that indicate an error. If a error occurs, the corresponding bit is set and maintained until it is acknowledged.

Data type	Values
USINT	See the bit structure.

Bit structure:

Bit	Name	Value	Information
0	StartBitError	0	No error
		1	Start bit error occurred <sup>1)</sup>
1	StopBitError	0	No error
		1	Stop bit error occurred <sup>1)</sup>
2	ParityError	0	No error
		1	Parity bit error occurred <sup>1)</sup>
3	RXoverrun	0	No error
		1	Receive buffer overflow occurred <sup>2)</sup>
4 - 7	Reserved	0	

- 1) This error can result from things such as mismatched interface configurations or problems with the wiring.
- 2) This data point reports a receive buffer overrun. The buffer capacity on the module is exhausted and all subsequent data arriving at the interface is lost. An overrun always means that the data received on the module is not read fast enough by the higher-level system. The solution here is to optimize the cycle times of all transfer routes and task classes involved and utilize the available handshake options.

### 9.9.2 Acknowledging the status bits

Name:  
QuitStartBitError  
QuitStopBitError  
QuitParityError  
QuitRXoverrun

This register is used to transfer the individual bits that acknowledge an indicated error state. After one of the bits has been set, it can be reset using the corresponding acknowledgment bit.

If the error is still actively pending, the error status bit is not deleted. The acknowledgment bit can only be reset if the error status bit is no longer set.

Data type	Values
USINT	See the bit structure.

Bit structure:

Bit	Name	Value	Information
0	QuitStartBitError	0	No acknowledgment
		1	Acknowledge start bit error
1	QuitStopBitError	0	No acknowledgment
		1	Acknowledge stop bit error
2	QuitParityError	0	No acknowledgment
		1	Acknowledge parity bit error
3	QuitRXoverrun	0	No acknowledgment
		1	Acknowledge receive buffer overflow error
4 - 7	Reserved	0	

## 9.10 Flatstream communication

### 9.10.1 Introduction

B&R offers an additional communication method for some modules. "Flatstream" was designed for X2X and POWERLINK networks and allows data transmission to be adapted to individual demands. Although this method is not 100% real-time capable, it still allows data transfer to be handled more efficiently than with standard cyclic polling.




Figure 1: 3 types of communication

Flatstream extends cyclic and acyclic data queries. With Flatstream communication, the module acts as a bridge. The module is used to pass CPU queries directly on to the field device.

### 9.10.2 Message, segment, sequence, MTU

The physical properties of the bus system limit the amount of data that can be transmitted during one bus cycle. With Flatstream communication, all messages are viewed as part of a continuous data stream. Long data streams must be broken down into several fragments that are sent one after the other. To understand how the receiver puts these fragments back together to get the original information, it is important to understand the difference between a message, a segment, a sequence and an MTU.

#### Message

A message refers to information exchanged between 2 communicating partner stations. The length of a message is not restricted by the Flatstream communication method. Nevertheless, module-specific limitations must be considered.

#### Segment (logical division of a message):

A segment has a finite size and can be understood as a section of a message. The number of segments per message is arbitrary. So that the recipient can correctly reassemble the transferred segments, each segment is preceded by a byte with additional information. This control byte contains information such as the length of a segment and whether the approaching segment completes the message. This makes it possible for the receiving station to interpret the incoming data stream correctly.

#### Sequence (how a segment must be arranged physically):

The maximum size of a sequence corresponds to the number of enabled Rx or Tx bytes (later: "MTU"). The transmitting station splits the transmit array into valid sequences. These sequences are then written successively to the MTU and transferred to the receiving station where they are put back together again. The receiver stores the incoming sequences in a receive array, obtaining an image of the data stream in the process.

With Flatstream communication, the number of sequences sent are counted. Successfully transferred sequences must be acknowledged by the receiving station to ensure the integrity of the transfer.

#### MTU (Maximum Transmission Unit) - Physical transport:

MTU refers to the enabled USINT registers used with Flatstream. These registers can accept at least one sequence and transfer it to the receiving station. A separate MTU is defined for each direction of communication. OutputMTU defines the number of Flatstream Tx bytes, and InputMTU specifies the number of Flatstream Rx bytes. The MTUs are transported cyclically via the X2X Link network, increasing the load with each additional enabled USINT register.

#### Properties

Flatstream messages are not transferred cyclically or in 100% real time. Many bus cycles may be needed to transfer a particular message. Although the Rx and Tx registers are exchanged between the transmitter and the receiver cyclically, they are only processed further if explicitly accepted by register "InputSequence" or "OutputSequence".

#### Behavior in the event of an error (brief summary)

The protocol for X2X and POWERLINK networks specifies that the last valid values should be retained when disturbances occur. With conventional communication (cyclic/acyclic data queries), this type of error can generally be ignored.

In order for communication to also take place without errors using Flatstream, all of the sequences issued by the receiver must be acknowledged. If Forward functionality is not used, then subsequent communication is delayed for the length of the disturbance.

If Forward functionality is being used, the receiving station receives a transmission counter that is incremented twice. The receiver stops, i.e. it no longer returns any acknowledgments. The transmitting station uses SequenceAck to determine that the transmission was faulty and that all affected sequences must be repeated.

### 9.10.3 The Flatstream principle

#### Requirement

Before Flatstream can be used, the respective communication direction must be synchronized, i.e. both communication partners cyclically query the sequence counter on the opposite station. This checks to see if there is new data that should be accepted.

#### Communication

If a communication partner wants to transmit a message to its opposite station, it should first create a transmit array that corresponds to Flatstream conventions. This allows the Flatstream data to be organized very efficiently without having to block other important resources.




Figure 2: Flatstream communication

#### Procedure

The first thing that happens is that the message is broken into valid segments of up to 63 bytes, and the corresponding control bytes are created. The data is formed into a data stream made up of one control bytes per associated segment. This data stream can be written to the transmit array. The maximum size of each array element matches that of the enabled MTU so that one element corresponds to one sequence.

If the array has been completely created, the transmitter checks whether the MTU is permitted to be refilled. It then copies the first element of the array or the first sequence to the Tx byte registers. The MTU is transported to the receiver station via X2X Link and stored in the corresponding Rx byte registers. To signal that the data should be accepted by the receiver, the transmitter increases its SequenceCounter.

If the communication direction is synchronized, the opposite station detects the incremented SequenceCounter. The current sequence is appended to the receive array and acknowledged by SequenceAck. This acknowledgment signals to the transmitter that the MTU can now be refilled.

If the transfer is successful, the data in the receive array will correspond 100% to the data in the transmit array. During the transfer, the receiving station must detect and evaluate the incoming control bytes. A separate receive array should be created for each message. This allows the receiver to immediately begin further processing of messages once they have been completely transferred.

## 9.10.4 Registers for Flatstream mode

5 registers are available for configuring Flatstream. The default configuration can be used to transmit small amounts of data relatively easily.

### Information:

The CPU communicates directly with the field device via registers "OutputSequence" and "InputSequence" as well as the enabled Tx and Rx bytes. For this reason, the user needs to have sufficient knowledge of the communication protocol being used on the field device.

### 9.10.4.1 Flatstream configuration

To use Flatstream, the program sequence must first be expanded. The cycle time of the Flatstream routines must be set to a multiple of the bus cycle. Other program routines should be implemented in Cyclic #1 to ensure data consistency.

At the absolute minimum, registers "InputMTU" and "OutputMTU" must be set. All other registers are filled in with default values at the beginning and can be used immediately. These registers are used for additional options, e.g. to transfer data in a more compact way or to increase the efficiency of the general procedure.

The Forward registers extend the functionality of the Flatstream protocol. This functionality is useful for substantially increasing the Flatstream data rate, but it also requires quite a bit of extra work when creating the program sequence.

#### 9.10.4.1.1 Number of enabled Tx and Rx bytes

Name:

OutputMTU

InputMTU

These registers define the number of enabled Tx or Rx bytes and thus also the maximum size of a sequence. The user must consider that the more bytes made available also means a higher load on the bus system.

### Information:

In the rest of this description, the names "OutputMTU" and "InputMTU" do not refer to the registers explained here. Instead, they are used as synonyms for the currently enabled Tx or Rx bytes.

Data type	Values
USINT	See the module-specific register overview (theoretically: 3 to 27).

### 9.10.4.2 Flatstream operation

When using Flatstream, the communication direction is very important. For transmitting data to a module (output direction), Tx bytes are used. For receiving data from a module (input direction), Rx bytes are used.

Registers "OutputSequence" and "InputSequence" are used to control and ensure that communication is taking place properly, i.e. the transmitter issues the directive that the data should be accepted and the receiver acknowledges that a sequence has been transferred successfully.

#### 9.10.4.2.1 Format of input and output bytes

Name:

"Format of Flatstream" in Automation Studio

On some modules, this function can be used to set how the Flatstream input and output bytes (Tx or Rx bytes) are transferred.

- **Packed:** Data is transferred as an array.
- **Byte-by-byte:** Data is transferred as individual bytes.

#### 9.10.4.2.2 Transport of payload data and control bytes

Name:

TxByte1 to TxByteN

RxByte1 to RxByteN

(The value the number N is different depending on the bus controller model used.)

The Tx and Rx bytes are cyclic registers used to transport the payload data and the necessary control bytes. The number of active Tx and Rx bytes is taken from the configuration of registers "OutputMTU" and "InputMTU", respectively.

In the user program, only the Tx and Rx bytes from the CPU can be used. The corresponding counterparts are located in the module and are not accessible to the user. For this reason, the names were chosen from the point of view of the CPU.

- "T" - "Transmit" →CPU *transmits* data to the module.
- "R" - "Receive" →CPU *receives* data from the module.

Data type	Values
USINT	0 to 255

#### 9.10.4.2.3 Control bytes

In addition to the payload data, the Tx and Rx bytes also transfer the necessary control bytes. These control bytes contain additional information about the data stream so that the receiver can reconstruct the original message from the transferred segments.

#### Bit structure of a control byte

Bit	Description	Value	Information
0 - 5	SegmentLength	0 - 63	Size of the subsequent segment in bytes (default: Max. MTU size - 1)
6	nextCBPos	0	Next control byte at the beginning of the next MTU
		1	Next control byte directly after the end of the current segment
7	MessageEndBit	0	Message continues after the subsequent segment
		1	Message ended by the subsequent segment

#### SegmentLength

The segment length lets the receiver know the length of the coming segment. If the set segment length is insufficient for a message, then the information must be distributed over several segments. In these cases, the actual end of the message is detected using bit 7 of the control byte.

#### Information:

**The control byte is not included in the calculation to determine the segment length. The segment length is only derived from the bytes of payload data.**

#### nextCBPos

This bit indicates the position where the next control byte is to be expected. This information is especially important when using option "MultiSegmentMTU".

When using Flatstream communication with multi-segment MTUs, the next control byte is no longer expected in the first Rx byte of the subsequent MTU, but transferred directly after the current segment.

MessageEndBit

"MessageEndBit" is set if the subsequent segment completes a message. The message has then been completely transferred and is ready for further processing.

**Information:**

**In the output direction, this bit must also be set if one individual segment is enough to hold the entire message. The module will only process a message internally if this identifier is detected. The size of the message being transferred can be calculated by adding all of the message's segment lengths together.**

Flatstream formula for calculating message length:

Message [bytes] = Segment lengths (all CBs without ME) + Segment length (of the first CB with ME)	CB	Control byte
	ME	MessageEndBit

**9.10.4.2.4 Communication status of the CPU**

Name:

OutputSequence

Register "OutputSequence" contains information about the communication status of the CPU. It is written by the CPU and read by the module.

Data type	Values
USINT	See the bit structure.

Bit structure:

Bit	Description	Value	Information
0 - 2	OutputSequenceCounter	0 - 7	Counter for the sequences issued in the output direction
3	OutputSyncBit	0	Output direction disabled
		1	Output direction enabled
4 - 6	InputSequenceAck	0 - 7	Mirrors InputSequenceCounter
7	InputSyncAck	0	Input direction not ready (disabled)
		1	Input direction ready (enabled)

OutputSequenceCounter

The OutputSequenceCounter is a continuous counter of sequences that have been issued by the CPU. The CPU uses OutputSequenceCounter to direct the module to accept a sequence (the output direction must be synchronized when this happens).

OutputSyncBit

The CPU uses OutputSyncBit to attempt to synchronize the output channel.

InputSequenceAck

InputSequenceAck is used for acknowledgment. The value of InputSequenceCounter is mirrored if the CPU has received a sequence successfully.

InputSyncAck

The InputSyncAck bit acknowledges the synchronization of the input channel for the module. This indicates that the CPU is ready to receive data.

### 9.10.4.2.5 Communication status of the module

Name:  
InputSequence

Register "InputSequence" contains information about the communication status of the module. It is written by the module and should only be read by the CPU.

Data type	Values
USINT	See the bit structure.

Bit structure:

Bit	Description	Value	Information
0 - 2	InputSequenceCounter	0 - 7	Counter for sequences issued in the input direction
3	InputSyncBit	0	Not ready (disabled)
		1	Ready (enabled)
4 - 6	OutputSequenceAck	0 - 7	Mirrors OutputSequenceCounter
7	OutputSyncAck	0	Not ready (disabled)
		1	Ready (enabled)

#### InputSequenceCounter

The InputSequenceCounter is a continuous counter of sequences that have been issued by the module. The module uses InputSequenceCounter to direct the CPU to accept a sequence (the input direction must be synchronized when this happens).

#### InputSyncBit

The module uses InputSyncBit to attempt to synchronize the input channel.

#### OutputSequenceAck

OutputSequenceAck is used for acknowledgment. The value of OutputSequenceCounter is mirrored if the module has received a sequence successfully.

#### OutputSyncAck

The OutputSyncAck bit acknowledges the synchronization of the output channel for the CPU. This indicates that the module is ready to receive data.

### 9.10.4.2.6 Relationship between OutputSequence and InputSequence




Figure 3: Relationship between OutputSequence and InputSequence

Registers "OutputSequence" and "InputSequence" are logically composed of 2 half-bytes. The low part signals to the opposite station whether a channel should be opened or if data should be accepted. The high part is to acknowledge that the requested action was carried out.

#### SyncBit and SyncAck

If SyncBit and SyncAck are set in one communication direction, then the channel is considered "synchronized", i.e. it is possible to send messages in this direction. The status bit of the opposite station must be checked cyclically. If SyncAck has been reset, then SyncBit on that station must be adjusted. Before new data can be transferred, the channel must be resynchronized.

#### SequenceCounter and SequenceAck

The communication partners cyclically check whether the low nibble on the opposite station changes. When one of the communication partners finishes writing a new sequence to the MTU, it increments its SequenceCounter. The current sequence is then transmitted to the receiver, which acknowledges its receipt with SequenceAck. In this way, a "handshake" is initiated.

#### Information:

**If communication is interrupted, segments from the unfinished message are discarded. All messages that were transferred completely are processed.**

### 9.10.4.3 Synchronization

During synchronization, a communication channel is opened. It is important to make sure that a module is present and that the current value of SequenceCounter is stored on the station receiving the message. Flatstream can handle full-duplex communication. This means that both channels / communication directions can be handled separately. They must be synchronized independently so that simplex communication can theoretically be carried out as well.

#### Synchronization in the output direction (CPU as the transmitter):

The corresponding synchronization bits (OutputSyncBit and OutputSyncAck) are reset. Because of this, Flatstream cannot be used at this point in time to transfer messages from the CPU to the module.

#### Algorithm

1) The CPU must write 000 to OutputSequenceCounter and reset OutputSyncBit. The CPU must cyclically query the high nibble of register "InputSequence" (checks for 000 in OutputSequenceAck and 0 in OutputSyncAck). <i>The module does not accept the current contents of InputMTU since the channel is not yet synchronized.</i> <i>The module matches OutputSequenceAck and OutputSyncAck to the values of OutputSequenceCounter and OutputSyncBit.</i>
2) If the CPU registers the expected values in OutputSequenceAck and OutputSyncAck, it is permitted to increment OutputSequenceCounter. The CPU continues cyclically querying the high nibble of register "OutputSequence" (checks for 001 in OutputSequenceAck and 0 in InputSyncAck). <i>The module does not accept the current contents of InputMTU since the channel is not yet synchronized.</i> <i>The module matches OutputSequenceAck and OutputSyncAck to the values of OutputSequenceCounter and OutputSyncBit.</i>
3) If the CPU registers the expected values in OutputSequenceAck and OutputSyncAck, it is permitted to increment OutputSequenceCounter. The CPU continues cyclically querying the high nibble of register "OutputSequence" (checks for 001 in OutputSequenceAck and 1 in InputSyncAck).
<b>Note:</b> Theoretically, data can be transferred from this point forward. However, it is still recommended to wait until the output direction is completely synchronized before transferring data. <i>The module sets OutputSyncAck.</i>
The output direction is synchronized, and the CPU can transmit data to the module.

#### Synchronization in the input direction (CPU as the receiver):

The corresponding synchronization bits (InputSyncBit and InputSyncAck) are reset. Because of this, Flatstream cannot be used at this point in time to transfer messages from the module to the CPU.

#### Algorithm

<i>The module writes 000 to InputSequenceCounter and resets InputSyncBit.</i> <i>The module monitors the high nibble of register "OutputSequence" and expects 000 in InputSequenceAck and 0 in InputSyncAck.</i>
1) The CPU is not permitted to accept the current contents of InputMTU since the channel is not yet synchronized. The CPU has to match InputSequenceAck and InputSyncAck to the values of InputSequenceCounter and InputSyncBit. <i>If the module registers the expected values in InputSequenceAck and InputSyncAck, it increments InputSequenceCounter.</i> <i>The module monitors the high nibble of register "OutputSequence" and expects 001 in InputSequenceAck and 0 in InputSyncAck.</i>
2) The CPU is not permitted to accept the current contents of InputMTU since the channel is not yet synchronized. The CPU has to match InputSequenceAck and InputSyncAck to the values of InputSequenceCounter and InputSyncBit. <i>If the module registers the expected values in InputSequenceAck and InputSyncAck, it sets InputSyncBit.</i> <i>The module monitors the high nibble of register "OutputSequence" and expects 1 in InputSyncAck.</i>
3) The CPU is permitted to set InputSyncAck.
<b>Note:</b> Theoretically, data could already be transferred in this cycle. If InputSyncBit is set and InputSequenceCounter has been increased by 1, the values in the enabled Rx bytes must be accepted and acknowledged (see also "Communication in the input direction").
The input direction is synchronized, and the module can transmit data to the CPU.

### 9.10.4.4 Transmitting and receiving

If a channel is synchronized, then the opposite station is ready to receive messages from the transmitter. Before the transmitter can send data, it needs to first create a transmit array in order to meet Flatstream requirements.

The transmitting station must also generate a control byte for each segment created. This control byte contains information about how the subsequent part of the data being transferred should be processed. The position of the next control byte in the data stream can vary. For this reason, it must be clearly defined at all times when a new control byte is being transmitted. The first control byte is always in the first byte of the first sequence. All subsequent positions are determined recursively.

Flatstream formula for calculating the position of the next control byte:

$$\text{Position (of the next control byte)} = \text{Current position} + 1 + \text{Segment length}$$

#### Example

3 autonomous messages (7 bytes, 2 bytes and 9 bytes) are being transmitted using an MTU with a width of 7 bytes. The rest of the configuration corresponds to the default settings.




Figure 4: Transmit/Receive array (default)

First, the messages must be split into segments. In the default configuration, it is important to ensure that each sequence can hold an entire segment, including the associated control byte. The sequence is limited to the size of the enable MTU. In other words, a segment must be at least 1 byte smaller than the MTU.

MTU = 7 bytes → Max. segment length = 6 bytes

- Message 1 (7 bytes)
  - ⇒ First segment = Control byte + 6 bytes of data
  - ⇒ Second segment = Control byte + 1 data byte
- Message 2 (2 bytes)
  - ⇒ First segment = Control byte + 2 bytes of data
- Message 3 (9 bytes)
  - ⇒ First segment = Control byte + 6 bytes of data
  - ⇒ Second segment = Control byte + 3 data bytes
- No more messages
  - ⇒ C0 control byte

A unique control byte must be generated for each segment. In addition, the C0 control byte is generated to keep communication on standby.

C0 (control byte 0)		C1 (control byte 1)		C2 (control byte 2)	
- SegmentLength (0)	= 0	- SegmentLength (6)	= 6	- SegmentLength (1)	= 1
- nextCBPos (0)	= 0	- nextCBPos (0)	= 0	- nextCBPos (0)	= 0
- MessageEndBit (0)	= 0	- MessageEndBit (0)	= 0	- MessageEndBit (1)	= 128
Control byte	Σ 0	Control byte	Σ 6	Control byte	Σ 129

Table 3: Flatstream determination of the control bytes for the default configuration example (part 1)

C3 (control byte 3)		C4 (control byte 4)		C5 (control byte 5)	
- SegmentLength (2)	= 2	- SegmentLength (6)	= 6	- SegmentLength (3)	= 3
- nextCBPos (0)	= 0	- nextCBPos (0)	= 0	- nextCBPos (0)	= 0
- MessageEndBit (1)	= 128	- MessageEndBit (0)	= 0	- MessageEndBit (1)	= 128
Control byte	Σ 130	Control byte	Σ 6	Control byte	Σ 131

Table 4: Flatstream determination of the control bytes for the default configuration example (part 2)

### 9.10.4.5 Transmitting data to a module (output)

When transmitting data, the transmit array must be generated in the application program. Sequences are then transferred one by one using Flatstream and received by the module.

#### Information:

Although all B&R modules with Flatstream communication always support the most compact transfers in the output direction, it is recommended to use the same design for the transfer arrays in both communication directions.




Figure 5: Flatstream communication (output)

#### Message smaller than OutputMTU

The length of the message is initially smaller than `OutputMTU`. In this case, one sequence would be sufficient to transfer the entire message and the necessary control byte.

#### Algorithm

<p><i>Cyclic status query:</i></p> <ul style="list-style-type: none"> <li>- The module monitors <code>OutputSequenceCounter</code>.</li> </ul>
<p>0) Cyclic checks:</p> <ul style="list-style-type: none"> <li>- The CPU must check <code>OutputSyncAck</code>.</li> <li>→ If <code>OutputSyncAck = 0</code>: Reset <code>OutputSyncBit</code> and resynchronize the channel.</li> <li>- The CPU must check whether <code>OutputMTU</code> is enabled.</li> <li>→ If <code>OutputSequenceCounter &gt; InputSequenceAck</code>: <code>MTU</code> is not enabled because the last sequence has not yet been acknowledged.</li> </ul>
<p>1) Preparation (create transmit array):</p> <ul style="list-style-type: none"> <li>- The CPU must split up the message into valid segments and create the necessary control bytes.</li> <li>- The CPU must add the segments and control bytes to the transmit array.</li> </ul>
<p>2) Transmit:</p> <ul style="list-style-type: none"> <li>- The CPU transfers the current element of the transmit array to <code>OutputMTU</code>.</li> <li>→ The <code>OutputMTU</code> is transferred cyclically to the module's transmit buffer but not processed further.</li> <li>- The CPU must increase <code>OutputSequenceCounter</code>.</li> </ul>
<p><i>Reaction:</i></p> <ul style="list-style-type: none"> <li>- The module accepts the bytes from the internal receive buffer and adds them to the internal receive array.</li> <li>- The module transmits acknowledgment and writes the value of <code>OutputSequenceCounter</code> to <code>OutputSequenceAck</code>.</li> </ul>
<p>3) Completion:</p> <ul style="list-style-type: none"> <li>- The CPU must monitor <code>OutputSequenceAck</code>.</li> <li>→ A sequence is only considered to have been transferred successfully if it has been acknowledged via <code>OutputSequenceAck</code>. In order to detect potential transfer errors in the last sequence as well, it is important to make sure that the length of the <i>Completion</i> phase is run through long enough.</li> </ul>
<p><b>Note:</b></p> <p>To monitor communication times exactly, the task cycles that have passed since the last increase of <code>OutputSequenceCounter</code> should be counted. In this way, the number of previous bus cycles necessary for the transfer can be measured. If the monitoring counter exceeds a predefined threshold, then the sequence can be considered lost.</p> <p>(The relationship of bus to task cycle can be influenced by the user so that the threshold value must be determined individually.)</p> <ul style="list-style-type: none"> <li>- Subsequent sequences are only permitted to be transmitted in the next bus cycle after the completion check has been carried out successfully.</li> </ul>

### Message larger than OutputMTU

The transmit array, which must be created in the program sequence, consists of several elements. The user has to arrange the control and data bytes correctly and transfer the array elements one after the other. The transfer algorithm remains the same and is repeated starting at the point *Cyclic checks*.

#### General flow chart




Figure 6: Flow chart for the output direction

### 9.10.4.6 Receiving data from a module (input)

When receiving data, the transmit array is generated by the module, transferred via Flatstream and must then be reproduced in the receive array. The structure of the incoming data stream can be set with the mode register. The algorithm for receiving the data does not change in this regard.




Figure 7: Flatstream communication (input)

#### Algorithm

<p>0) Cyclic status query:</p> <ul style="list-style-type: none"> <li>- The CPU must monitor <code>InputSequenceCounter</code>.</li> </ul>
<p>Cyclic checks:</p> <ul style="list-style-type: none"> <li>- The module checks <code>InputSyncAck</code>.</li> <li>- The module checks <code>InputSequenceAck</code>.</li> </ul>
<p>Preparation:</p> <ul style="list-style-type: none"> <li>- The module forms the segments and control bytes and creates the transmit array.</li> </ul>
<p>Action:</p> <ul style="list-style-type: none"> <li>- The module transfers the current element of the internal transmit array to the internal transmit buffer.</li> <li>- The module increases <code>InputSequenceCounter</code>.</li> </ul>
<p>1) Receiving (as soon as <code>InputSequenceCounter</code> is increased):</p> <ul style="list-style-type: none"> <li>- The CPU must apply data from <code>InputMTU</code> and append it to the end of the receive array.</li> <li>- The CPU must match <code>InputSequenceAck</code> to <code>InputSequenceCounter</code> of the sequence currently being processed.</li> </ul>
<p>Completion:</p> <ul style="list-style-type: none"> <li>- The module monitors <code>InputSequenceAck</code>.</li> <li>→ A sequence is only considered to have been transferred successfully if it has been acknowledged via <code>InputSequenceAck</code>.</li> <li>- Subsequent sequences are only transmitted in the next bus cycle after the completion check has been carried out successfully.</li> </ul>

General flow chart




Figure 8: Flow chart for the input direction

#### 9.10.4.7 Details

**It is recommended to store transferred messages in separate receive arrays.**

After a set MessageEndBit is transmitted, the subsequent segment should be added to the receive array. The message is then complete and can be passed on internally for further processing. A new/separate array should be created for the next message.

#### **Information:**

**When transferring with MultiSegmentMTUs, it is possible for several small messages to be part of one sequence. In the program, it is important to make sure that a sufficient number of receive arrays can be managed. The acknowledge register is only permitted to be adjusted after the entire sequence has been applied.**

**If SequenceCounter is incremented by more than one counter, an error is present.**

Note: This situation is very unlikely when operating without "Forward" functionality.

In this case, the receiver stops. All additional incoming sequences are ignored until the transmission with the correct SequenceCounter is retried. This response prevents the transmitter from receiving any more acknowledgments for transmitted sequences. The transmitter can identify the last successfully transferred sequence from the opposite station's SequenceAck and continue the transfer from this point.

**Acknowledgments must be checked for validity.**

If the receiver has successfully accepted a sequence, it must be acknowledged. The receiver takes on the value of SequenceCounter sent along with the transmission and matches SequenceAck to it. The transmitter reads SequenceAck and registers the successful transmission. If the transmitter acknowledges a sequence that has not yet been dispatched, then the transfer must be interrupted and the channel resynchronized. The synchronization bits are reset and the current/incomplete message is discarded. It must be sent again once the channel has been resynchronized.

### 9.10.4.8 Flatstream mode

Name:  
FlatstreamMode

In the input direction, the transmit array is generated automatically. This register offers 2 options to the user that allow an incoming data stream to have a more compact arrangement. Once enabled, the program code for evaluation must be adapted accordingly.

#### Information:

All B&R modules that offer Flatstream mode support options "Large segments" and "MultiSegmentMTUs" in the output direction. Compact transfer must be explicitly allowed only in the input direction.

Bit structure:

Bit	Description	Value	Information
0	MultiSegmentMTU	0	Not allowed (default)
		1	Permitted
1	Large segments	0	Not allowed (default)
		1	Permitted
2 - 7	Reserved		

#### Standard

By default, both options relating to compact transfer in the input direction are disabled.

1. The module only forms segments that are at least one byte smaller than the enabled MTU. Each sequence begins with a control byte so that the data stream is clearly structured and relatively easy to evaluate.
2. Since a Flatstream message is permitted to be any length, the last segment of the message frequently does not fill up all of the MTU's space. By default, the remaining bytes during this type of transfer cycle are not used.




Figure 9: Message arrangement in the MTU (default)

### MultiSegmentMTUs allowed

With this option, InputMTU is completely filled (if enough data is pending). The previously unfilled Rx bytes transfer the next control bytes and their segments. This allows the enabled Rx bytes to be used more efficiently.




Figure 10: Arrangement of messages in the MTU (MultiSegmentMTUs)

### Large segments allowed:

When transferring very long messages or when enabling only very few Rx bytes, then a great many segments must be created by default. The bus system is more stressed than necessary since an additional control byte must be created and transferred for each segment. With option "Large segments", the segment length is limited to 63 bytes independently of InputMTU. One segment is permitted to stretch across several sequences, i.e. it is possible for "pure" sequences to occur without a control byte.

#### Information:

It is still possible to split up a message into several segments, however. If this option is used and messages with more than 63 bytes occur, for example, then messages can still be split up among several segments.




Figure 11: Arrangement of messages in the MTU (large segments)

### Using both options

Using both options at the same time is also permitted.




Figure 12: Arrangement of messages in the MTU (large segments and MultiSegmentMTUs)

### 9.10.4.9 Adjusting the Flatstream

If the way messages are structured is changed, then the way data in the transmit/receive array is arranged is also different. The following changes apply to the example given earlier.

#### MultiSegmentMTU

If MultiSegmentMTUs are allowed, then "open positions" in an MTU can be used. These "open positions" occur if the last segment in a message does not fully use the entire MTU. MultiSegmentMTUs allow these bits to be used to transfer the subsequent control bytes and segments. In the program sequence, the "nextCBPos" bit in the control byte is set so that the receiver can correctly identify the next control byte.

#### Example

3 autonomous messages (7 bytes, 2 bytes and 9 bytes) are being transmitted using an MTU with a width of 7 bytes. The configuration allows the transfer of MultiSegmentMTUs.




Figure 13: Transmit/receive array (MultiSegmentMTUs)

First, the messages must be split into segments. As in the default configuration, it is important for each sequence to begin with a control byte. The free bits in the MTU at the end of a message are filled with data from the following message, however. With this option, the "nextCBPos" bit is always set if payload data is transferred after the control byte.

MTU = 7 bytes → Max. segment length = 6 bytes

- Message 1 (7 bytes)
  - ⇒ First segment = Control byte + 6 bytes of data (MTU full)
  - ⇒ Second segment = Control byte + 1 byte of data (MTU still has 5 open bytes)
- Message 2 (2 bytes)
  - ⇒ First segment = Control byte + 2 bytes of data (MTU still has 2 open bytes)
- Message 3 (9 bytes)
  - ⇒ First segment = Control byte + 1 byte of data (MTU full)
  - ⇒ Second segment = Control byte + 6 bytes of data (MTU full)
  - ⇒ Third segment = Control byte + 2 bytes of data (MTU still has 4 open bytes)
- No more messages
  - ⇒ C0 control byte

A unique control byte must be generated for each segment. In addition, the C0 control byte is generated to keep communication on standby.

C1 (control byte 1)		C2 (control byte 2)		C3 (control byte 3)	
- SegmentLength (6)	= 6	- SegmentLength (1)	= 1	- SegmentLength (2)	= 2
- nextCBPos (1)	= 64	- nextCBPos (1)	= 64	- nextCBPos (1)	= 64
- MessageEndBit (0)	= 0	- MessageEndBit (1)	= 128	- MessageEndBit (1)	= 128
Control byte	Σ 70	Control byte	Σ 193	Control byte	Σ 194

Table 5: Flatstream determination of the control bytes for the MultiSegmentMTU example (part 1)

## Warning!

The second sequence is only permitted to be acknowledged via SequenceAck if it has been completely processed. In this example, there are 3 different segments within the second sequence, i.e. the program must include enough receive arrays to handle this situation.

C4 (control byte 4)		C5 (control byte 5)		C6 (control byte 6)	
- SegmentLength (1)	= 1	- SegmentLength (6)	= 6	- SegmentLength (2)	= 2
- nextCBPos (6)	= 6	- nextCBPos (1)	= 64	- nextCBPos (1)	= 64
- MessageEndBit (0)	= 0	- MessageEndBit (1)	= 0	- MessageEndBit (1)	= 128
Control byte	Σ 7	Control byte	Σ 70	Control byte	Σ 194

Table 6: Flatstream determination of the control bytes for the MultiSegmentMTU example (part 2)

### Large segments

Segments are limited to a maximum of 63 bytes. This means they can be larger than the active MTU. These large segments are divided among several sequences when transferred. It is possible for sequences to be completely filled with payload data and not have a control byte.

#### Information:

**It is still possible to subdivide a message into several segments so that the size of a data packet does not also have to be limited to 63 bytes.**

#### Example

3 autonomous messages (7 bytes, 2 bytes and 9 bytes) are being transmitted using an MTU with a width of 7 bytes. The configuration allows the transfer of large segments.




Figure 14: Transmit/receive array (large segments)

First, the messages must be split into segments. The ability to form large segments means that messages are split up less frequently, which results in fewer control bytes generated.

Large segments allowed → Max. segment length = 63 bytes

- Message 1 (7 bytes)
  - ⇒ First segment = Control byte + 7 bytes of data
- Message 2 (2 bytes)
  - ⇒ First segment = Control byte + 2 bytes of data
- Message 3 (9 bytes)
  - ⇒ First segment = Control byte + 9 bytes of data
- No more messages
  - ⇒ C0 control byte

A unique control byte must be generated for each segment. In addition, the C0 control byte is generated to keep communication on standby.

C1 (control byte 1)		C2 (control byte 2)		C3 (control byte 3)	
- SegmentLength (7)	= 7	- SegmentLength (2)	= 2	- SegmentLength (9)	= 9
- nextCBPos (0)	= 0	- nextCBPos (0)	= 0	- nextCBPos (0)	= 0
- MessageEndBit (1)	= 128	- MessageEndBit (1)	= 128	- MessageEndBit (1)	= 128
Control byte	Σ 135	Control byte	Σ 130	Control byte	Σ 137

Table 7: Flatstream determination of the control bytes for the large segment example

**Large segments and MultiSegmentMTU**

Example

3 autonomous messages (7 bytes, 2 bytes and 9 bytes) are being transmitted using an MTU with a width of 7 bytes. The configuration allows transfer of large segments as well as MultiSegmentMTUs.




Figure 15: Transmit/receive array (large segments and MultiSegmentMTUs)

First, the messages must be split into segments. If the last segment of a message does not completely fill the MTU, it is permitted to be used for other data in the data stream. Bit "nextCBPos" must always be set if the control byte belongs to a segment with payload data.

The ability to form large segments means that messages are split up less frequently, which results in fewer control bytes generated. Control bytes are generated in the same way as with option "Large segments".

Large segments allowed → Max. segment length = 63 bytes

- Message 1 (7 bytes)
  - ⇒ First segment = Control byte + 7 bytes of data
- Message 2 (2 bytes)
  - ⇒ First segment = Control byte + 2 bytes of data
- Message 3 (9 bytes)
  - ⇒ First segment = Control byte + 9 bytes of data
- No more messages
  - ⇒ C0 control byte

A unique control byte must be generated for each segment. In addition, the C0 control byte is generated to keep communication on standby.

C1 (control byte 1)		C2 (control byte 2)		C3 (control byte 3)	
- SegmentLength (7)	= 7	- SegmentLength (2)	= 2	- SegmentLength (9)	= 9
- nextCBPos (0)	= 0	- nextCBPos (0)	= 0	- nextCBPos (0)	= 0
- MessageEndBit (1)	= 128	- MessageEndBit (1)	= 128	- MessageEndBit (1)	= 128
Control byte	Σ 135	Control byte	Σ 130	Control byte	Σ 137

Table 8: Flatstream determination of the control bytes for the large segment and MultiSegmentMTU example

### 9.10.5 Example of Forward functionality on X2X Link

Forward functionality is a method that can be used to substantially increase the Flatstream data rate. The basic principle is also used in other technical areas such as "pipelining" for microprocessors.

#### 9.10.5.1 Function principle

X2X Link communication cycles through 5 different steps to transfer a Flatstream sequence. At least 5 bus cycles are therefore required to successfully transfer the sequence.

	Step I	Step II	Step III	Step IV	Step V
<b>Actions</b>	Transfer sequence from transmit array, increase SequenceCounter	Cyclic matching of MTU and module buffer	Append sequence to receive array Adjust SequenceAck	Cyclic matching of MTU and module buffer	Check SequenceAck
<b>Resource</b>	Sender (task to transmit)	Bus system (direction 1)	Recipient (task to receive)	Bus system (direction 2)	Sender (task for Ack checking)




Figure 16: Comparison of transfer without/with Forward

Each of the 5 steps (tasks) requires different resources. If Forward functionality is not used, the sequences are executed one after the other. Each resource is then only active if it is needed for the current sub-action.

With Forward, a resource that has executed its task can already be used for the next message. The condition for enabling the MTU is changed to allow for this. Sequences are then passed to the MTU according to the timing. The transmitting station no longer waits for an acknowledgment from SequenceAck, which means that the available bandwidth can be used much more efficiently.

In the most ideal situation, all resources are working during each bus cycle. The receiver still has to acknowledge every sequence received. Only when SequenceAck has been changed and checked by the transmitter is the sequence considered as having been transferred successfully.

### 9.10.5.2 Configuration

The Forward function must only be enabled for the input direction. 2 additional configuration registers are available for doing so. Flatstream modules have been optimized in such a way that they support this function. In the output direction, the Forward function can be used as soon as the size of OutputMTU is specified.

#### 9.10.5.2.1 Number of unacknowledged sequences

Name:  
Forward

With register "Forward", the user specifies how many unacknowledged sequences the module is permitted to transmit.

Recommendation:  
X2X Link: Max. 5  
POWERLINK: Max. 7

Data type	Values
USINT	1 to 7 Default: 1

#### 9.10.5.2.2 Delay time

Name:  
ForwardDelay

Register "ForwardDelay" is used to specify the delay time in  $\mu\text{s}$ . This is the amount of time the module has to wait after sending a sequence until it is permitted to write new data to the MTU in the following bus cycle. The program routine for receiving sequences from a module can therefore be run in a task class whose cycle time is slower than the bus cycle.

Data type	Values
UINT	0 to 65535 [ $\mu\text{s}$ ] Default: 0




Figure 17: Effect of ForwardDelay when using Flatstream communication with the Forward function

In the program, it is important to make sure that the CPU is processing all of the incoming InputSequences and InputMTUs. The ForwardDelay value causes delayed acknowledgment in the output direction and delayed reception in the input direction. In this way, the CPU has more time to process the incoming InputSequence or InputMTU.

### 9.10.5.3 Transmitting and receiving with Forward

The basic algorithm for transmitting and receiving data remains the same. With the Forward function, up to 7 unacknowledged sequences can be transmitted. Sequences can be transmitted without having to wait for the previous message to be acknowledged. Since the delay between writing and response is eliminated, a considerable amount of additional data can be transferred in the same time window.

#### Algorithm for transmitting

<p><i>Cyclic status query:</i></p> <ul style="list-style-type: none"> <li>- The module monitors OutputSequenceCounter.</li> </ul>
<p>0) Cyclic checks:</p> <ul style="list-style-type: none"> <li>- The CPU must check OutputSyncAck.</li> <li>→ If OutputSyncAck = 0: Reset OutputSyncBit and resynchronize the channel.</li> <li>- The CPU must check whether OutputMTU is enabled.</li> <li>→ If OutputSequenceCounter &gt; OutputSequenceAck + 7, then it is not enabled because the last sequence has not yet been acknowledged.</li> </ul>
<p>1) Preparation (create transmit array):</p> <ul style="list-style-type: none"> <li>- The CPU must split up the message into valid segments and create the necessary control bytes.</li> <li>- The CPU must add the segments and control bytes to the transmit array.</li> </ul>
<p>2) Transmit:</p> <ul style="list-style-type: none"> <li>- The CPU must transfer the current part of the transmit array to OutputMTU.</li> <li>- The CPU must increase OutputSequenceCounter for the sequence to be accepted by the module.</li> <li>- The CPU is then permitted to <i>transmit</i> in the next bus cycle if the MTU has been enabled.</li> </ul>
<p><i>The module responds since OutputSequenceCounter &gt; OutputSequenceAck:</i></p> <ul style="list-style-type: none"> <li>- The module accepts data from the internal receive buffer and appends it to the end of the internal receive array.</li> <li>- The module is acknowledged and the currently received value of OutputSequenceCounter is transferred to OutputSequenceAck.</li> <li>- The module queries the status cyclically again.</li> </ul>
<p>3) Completion (acknowledgment):</p> <ul style="list-style-type: none"> <li>- The CPU must check OutputSequenceAck cyclically.</li> <li>→ A sequence is only considered to have been transferred successfully if it has been acknowledged via OutputSequenceAck. In order to detect potential transfer errors in the last sequence as well, it is important to make sure that the algorithm is run through long enough.</li> </ul> <p><b>Note:</b></p> <p>To monitor communication times exactly, the task cycles that have passed since the last increase of OutputSequenceCounter should be counted. In this way, the number of previous bus cycles necessary for the transfer can be measured. If the monitoring counter exceeds a predefined threshold, then the sequence can be considered lost (the relationship of bus to task cycle can be influenced by the user so that the threshold value must be determined individually).</p>

#### Algorithm for receiving

<p>0) Cyclic status query:</p> <ul style="list-style-type: none"> <li>- The CPU must monitor InputSequenceCounter.</li> </ul>
<p><i>Cyclic checks:</i></p> <ul style="list-style-type: none"> <li>- The module checks InputSyncAck.</li> <li>- The module checks if InputMTU for enabling.</li> <li>→ Enabling criteria: InputSequenceCounter &gt; InputSequenceAck + Forward</li> </ul>
<p><i>Preparation:</i></p> <ul style="list-style-type: none"> <li>- The module forms the control bytes / segments and creates the transmit array.</li> </ul>
<p><i>Action:</i></p> <ul style="list-style-type: none"> <li>- The module transfers the current part of the transmit array to the receive buffer.</li> <li>- The module increases InputSequenceCounter.</li> <li>- The module waits for a new bus cycle after time from ForwardDelay has expired.</li> <li>- The module repeats the action if InputMTU is enabled.</li> </ul>
<p>1) Receiving (InputSequenceCounter &gt; InputSequenceAck):</p> <ul style="list-style-type: none"> <li>- The CPU must apply data from InputMTU and append it to the end of the receive array.</li> <li>- The CPU must match InputSequenceAck to InputSequenceCounter of the sequence currently being processed.</li> </ul>
<p><i>Completion:</i></p> <ul style="list-style-type: none"> <li>- The module monitors InputSequenceAck.</li> <li>→ A sequence is only considered to have been transferred successfully if it has been acknowledged via InputSequenceAck.</li> </ul>

## Details/Background

### 1. Illegal SequenceCounter size (counter offset)

Error situation: MTU not enabled

If the difference between SequenceCounter and SequenceAck during transmission is larger than permitted, a transfer error occurs. In this case, all unacknowledged sequences must be repeated with the old SequenceCounter value.

### 2. Checking an acknowledgment

After an acknowledgment has been received, a check must verify whether the acknowledged sequence has been transmitted and had not yet been unacknowledged. If a sequence is acknowledged multiple times, a severe error occurs. The channel must be closed and resynchronized (same behavior as when not using Forward).

### **Information:**

**In exceptional cases, the module can increment OutputSequenceAck by more than 1 when using Forward.**

**An error does not occur in this case. The CPU is permitted to consider all sequences up to the one being acknowledged as having been transferred successfully.**

### 3. Transmit and receive arrays

The Forward function has no effect on the structure of the transmit and receive arrays. They are created and must be evaluated in the same way.

### 9.10.5.4 Errors when using Forward

In industrial environments, it is often the case that many different devices from various manufacturers are being used side by side. The electrical and/or electromagnetic properties of these technical devices can sometimes cause them to interfere with one another. These kinds of situations can be reproduced and protected against in laboratory conditions only to a certain point.

Precautions have been taken for X2X Link transfers if this type of interference occurs. For example, if an invalid checksum occurs, the I/O system will ignore the data from this bus cycle and the receiver receives the last valid data once more. With conventional (cyclic) data points, this error can often be ignored. In the following cycle, the same data point is again retrieved, adjusted and transferred.

Using Forward functionality with Flatstream communication makes this situation more complex. The receiver receives the old data again in this situation as well, i.e. the previous values for SequenceAck/SequenceCounter and the old MTU.

#### Loss of acknowledgment (SequenceAck)

If a SequenceAck value is lost, then the MTU was already transferred properly. For this reason, the receiver is permitted to continue processing with the next sequence. The SequenceAck is aligned with the associated SequenceCounter and sent back to the transmitter. Checking the incoming acknowledgments shows that all sequences up to the last one acknowledged have been transferred successfully (see sequences 1 and 2 in the image).

#### Loss of transmission (SequenceCounter, MTU):

If a bus cycle drops out and causes the value of SequenceCounter and/or the filled MTU to be lost, then no data reaches the receiver. At this point, the transmission routine is not yet affected by the error. The time-controlled MTU is released again and can be rewritten to.

The receiver receives SequenceCounter values that have been incremented several times. For the receive array to be put together correctly, the receiver is only permitted to process transmissions whose SequenceCounter has been increased by one. The incoming sequences must be ignored, i.e. the receiver stops and no longer transmits back any acknowledgments.

If the maximum number of unacknowledged sequences has been sent and no acknowledgments are returned, the transmitter must repeat the affected SequenceCounter and associated MTUs (see sequence 3 and 4 in the image).




Figure 18: Effect of a lost bus cycle

#### Loss of acknowledgment

In sequence 1, the acknowledgment is lost due to disturbance. Sequences 1 and 2 are therefore acknowledged in Step V of sequence 2.

#### Loss of transmission

In sequence 3, the entire transmission is lost due to disturbance. The receiver stops and no longer sends back any acknowledgments.

The transmitting station continues transmitting until it has issued the maximum permissible number of unacknowledged transmissions.

5 bus cycles later at the earliest (depending on the configuration), it begins resending the unsuccessfully sent transmissions.

### 9.11 Serial with FlatStream

When using FlatStream communication, the module acts as a bridge between the X2X Link master and an intelligent field device connected to the module. FlatStream mode can be used for either point-to-point connections as well as for multidrop systems. Specific algorithms such as timeout and checksum monitoring are usually managed automatically. During normal operation, the user does not have access to these details.

In a serial network, the module is always the master (DTE). Various adjustments can be made to ensure that signals are transmitted without errors.

The user can, for example, define a handshake algorithm or set the baud rate in order to adapt the transmission quality to the requirements of the application.

#### Operation

When using FlatStream, the general structure of the FlatStream frame must be maintained.

Input/Output sequence	Tx/Rx bytes	
(unchanged)	Control byte (unchanged)	Serial frame (without handshake or similar measures)

### 9.12 Acyclic frame size

Name:

AsynSize

When the stream is used, data is exchanged internally between the module and CPU. For this purpose, a defined amount of acyclic bytes is reserved for this slot.

Increasing the acyclic frame size leads to increased data throughput on this slot.

#### Information:

**This configuration involves a driver setting that cannot be changed during runtime!**

Data type	Value	Information
-	8 to 28	Acyclic frame size in bytes. Default = 24

### 9.13 Minimum cycle time

The minimum cycle time specifies the time up to which the bus cycle can be reduced without communication errors occurring. It is important to note that very fast cycles reduce the idle time available for handling monitoring, diagnostics and acyclic commands.

Minimum cycle time
200 µs

### 9.14 Minimum I/O update time

The minimum I/O update time specifies how far the bus cycle can be reduced so that an I/O update is performed in each cycle.

Minimum I/O update time
200 µs